

GAS APPLIANCE DIRECTIVE 2009/142/EC
EC TYPE EXAMINATION CERTIFICATE – MODULE B
ANNEX II Paragraph I

Certificate number E1382/5622/2 *Date of issue* 12/07/2016
ID number 0461CO1016

Fabricant NORTEK GLOBAL HVAC BELGIUM NV
Manufacturer J. & M. Sabbestraat 130A/000
Fabrikant B-8930 MENEN

Commercialisé Nortek Global HVAC France S.A.S.
Marketed Z.I. de Rosarge 230, rue de la dombes, Les Echets
Gecommercialiseerd FR - 01706 MIRIBEL Cedex

Marque commerc.
Trade mark GAZ INDUSTRIE
Handelsmerk

Type ULSA 25 - ULSA 35 - ULSA 50 - ULSA 75 - ULSA 100
Model ULSB 025 - ULSB 035 - ULSB 050 - ULSB 075 - ULSB 100
Type ULS 025 - ULS 035 - ULS 050 - ULS 075 - ULS 100

Genre d'appareil Non domestic condensing air heater
Kind of Product
Soort toestel


Type d'appareil B22P|C12|C32|C42|C62 (*Attention* : Some types are not used or are forbidden in certain
Appliance type countries. See CR 1749 and regulations in force in each country).
Type toestel

Countries of destination, appliance categories :

AL - AT - BE - BG - CH - CY - CZ - DE - DK - EE - ES - FI - FR - GB - GR - HU - HR - IE - IS - IT - LT -
LU - LV - MK - MT - NL - NO - PL - PT - RO - SE - SI - SK - TR

I2H // I2L // I2E // I2ELL // I2E(R) // I2E(S) // I2Er // I2Esi // I3+ // I3B/P // I3P // I2H3B/P
I2H3+ // I2L3P // I2E3P // I2H3P // I2E(R)3P // I2E(S)3P // I2Er3+ // I2Esi3+ // I2S3P
I2HS3P

G20-20 mbar // G25-25 mbar // G25-20 mbar // G20/G25-20/25 mbar
G30-(28-30) mbar // G30/G31-(28-30)/37 mbar // G30-50 mbar
G31-30 mbar // G31-50 mbar // G31-37mbar



Bernard Neve
Director